


Distributed Energy Resource Grid Integration

Sacramento Plug-in Electric Vehicle Collaborative
1/21/20

Powering forward. Together.




DERs and Grid Integration




- SMUD design standards plan for 5kW of peak load contribution per home
- Increasing DER adoption creates opportunities, and risks if not managed
- The addition of EVs and Building Electrification, could cause significant infrastructure upgrade costs without load flexibility
- Goal is to integrate these new loads and renewables as much as possible onto our existing grid

Post IRP Forecasted Load Growth



Transportation Electrification



Light Duty EV Evolution



- Largest residential loads will be EVs
- Subcompact → full-size long-range EVs creating options for for higher charging levels (19kW Tesla option)
- DCFC 50kW → 450kW
- 60% participating in our EV rate
- Opportunity for alignment with solar curtailment mitigation and avoiding possible new midnight peak
- Autonomous testing in CA


Medium & Heavy Duty EVs

- Interest and model availability increasing for electrification of commercial medium and heavy duty vehicles
- Class 8 Trucks: 1.5MW charging or higher
- West Coast Corridor Truck Charging – Electrifying I-5
- Fleet electrification: charge management and future-ready (V2G)
- Integrated solutions for customer load management



Building Electrification Forecast

Equivalent All-Electric Homes Electrified per Year



Building Electrification

- Momentum building based upon decarbonization
 - Built Environment TAC
 - 50+ Municipalities considering ordinances
 - CPUC unanimously opened up \$1B EE funding for electrification
- New LAX terminal all-electric, even restaurants
- Load management needed to avoid more costly upgrade options
 - Customer panel considerations
 - Utility infrastructure needs




Battery Storage Evolution

- Battery storage will help provide operational flexibility
- Declining prices in line with 2023
- LADWP “Record Setting Low Solar Power Price”
- Leveraging the value of storage: Grid & Customer



PV Forecast



DER Challenges and Opportunities from within the control room



Powering forward. Together.



Operational Considerations

Challenges	Opportunities
Localized Voltage Issues from over generation (PV)	Offset over generation conditions (EVs & Storage)
Resource Variability (PV)	Reduction of peak load (Demand Management, Storage)
Overloaded equipment (EV and Building Electrification)	Deferred or reduced capital investments
	Reduction of losses

Tools/Technology Gaps

Modeling of DERs


Forecasting of DERs

Visibility and control


PV: Power Quality

TX-0105732 [04/22/2019 to 04/23/2019] (in kWh)

Transformer Loading




Meter Voltage



PV: Hidden Load

Powerline-Elkhorn Substation




- System load (green line) is what was visible to the operators
- Actual customer usage (orange line) is the amount of load we need to be prepared to serve if solar production is impacted by cloud cover
- “Hidden load” is the difference between the green line and the orange line


PV: Resource Variability

Cloud Coverage Impact


- Thunder Storm
 - Loss of 40 MW in 15 minutes
 - equivalent to 330A in 69kV
 - Impacts to switching



Overloaded Equipment Transformer Loading



TX-01062652 [07/27/2019 to 07/29/2019] (in KVAH)



100kVA padmount transformer


- Serving 16 customers
- Design assumption of 5kW per home
- Originally built with 75kVA transformer

Overloaded in July


- 5pm – 8pm on July 28th

Overloaded Equipment Metered Usage


Meter 2091298 [07/27/2019 to 07/29/2019] (in KWh)



Meter 2091297 [07/27/2019 to 07/29/2019] (in KWh)



Meter 2096970 [07/27/2019 to 07/29/2019] (in KWh)



EV Customer 1

- Peak usage of 12.5kWh at 5pm on 7/28


EV Customer 2

- Peak usage of 16.5kWh at 7pm on 7/27
- 15.5kWh on 7/28 at 3am
- 14.5kWh on 7/28 at 3pm

EV Customer 3


- Peak usage of 8.5kW at 4pm on 7/28

Annual System Upgrade Costs Vs. EV's Installed



Commercial EV Charging is exposed to Demand Charge Barriers (high load / low energy)


- Demand Charges are rate mechanisms that key on maximum load per month
- Designed to help customers reduce electricity through put costs by separating energy costs from grid impact wear and tear costs
- DCFC / Large Commercial Charging loads vulnerable given low energy utilization



SMUD has a few options to address demand charges

- Low Energy Commercial Rate for uses less than 7300kWh/month (Approximately 15 DCFC charges / day at 16kWh each)
 - For Loads between 20kW and 299kW
 - No demand charges if lower than 7300kWh/month
 - Approximately \$0.138 when calculated across all seasons and assumes 75% of charging occurs off-peak (*SMUD GSN_T Rate)
- New Storage Shares product addresses demand charges for higher loads (Greater than 299kW)
 - SMUD builds and installs a grid scale battery storage facility and lets customers buy “shares” from that facility
 - SMUD builds the facility where we need it
 - Reduces customer capital costs
 - Provides more benefits to the grid/utility/all customers

Evolution of the Distribution System





Questions?